



Modine Manufacturing Company 1500 DeKoven Avenue, Racine Wisconsin
PH: 262-636-1200 Fax: 262-636-1665

Representative/Wholesaler of Modine Atherion Units,

The Atherion Commercial Packaged Ventilation Unit, model MPR, when properly maintained, will provide many years of trouble-free service in demanding conditions.

When the condenser fan assemblies were updated in March 2013, an L-shaped bracket was added for secondary support. It was determined recently that this bracket is redundant as there are other secondary support mechanisms in place. In isolated cases, this support bracket can come loose and potentially damage the condenser coil below. Units produced after June 2015 are not affected.

As a proactive measure, Modine recommends removing these brackets from the condenser fans. Take care to shut off power to the Atherion before beginning this procedure. The brackets are accessible by removing the four bolts that hold the fan guard in place, or by removing the panels on either side of the condenser assembly. The brackets may then be removed by hand by grabbing the lower part underneath the motor, then bending it back and forth until it snaps. The remaining edge may then be covered with tape.



Thank you for your business.